

Obiectivul: TEATRUL ALEXANDRU DAVILA PITESTI
Obiectul: INSTALATII TERMICE - CAMERA CENTRALA TERMICA

LISTA DE ECHIPAMENTE PUSE LA DISPOZITIE DE BENEFICIAR
(ANSAMBLU DE 2 CENTRALE CU BOILER DE INCALZIRE A APEI
INCLUZAND ACCESORII, CONECTICA SI AUTOMATIZARI SALUS)

Nr.crt.	Denumire	UM	CANT
0	1	2	3
1	CENTRALA VAILLANT ECOCRAFT, VKK 2006/3-E-H	BUC	2
2	SET DE BAZA PENTRU ADMISIA DE AER [M1]	BUC	2
3	MODUL CUPLARE CENTRALE MURALE IN CASCADA, VR 32	BUC	1
4	AUTOMATIZARE VAILLANT VRC 700	BUC	1
5	MODUL EXTENSIE VR 71	BUC	1
6	SENZOR STANDARD VR 10	BUC	2
7	BUTELIE DE EGALIZARE DN 80 , 21.5MC/H	BUC	1
8	DISPOZITIV MAGNETIC DE ELIMINARE A IMP., DN. 2"	BUC	1
9	SUPAPA DE SIGURANTA BIANCHI, REGLABILA 3-10 bar - 1 1/4"	BUC	4
10	VAS EXPANSIUNE PT INCALZIRE, VERTICAL,VAREM, 6 BAR 200L	BUC	2
11	POMPA ELECTRONICA DAB EVOPLUS, B 100/220.40 M	BUC	2
12	BOILER VAILLANT, VIH R 300/3 BR, 300LT	BUC	1
13	VAS EXPANSIUNE PT HIDROFOR,REFLEX DE, 10 BAR, 33L	BUC	1
14	GRUP SIGURANTA BOILERE VAILLANT [F1]	BUC	1
15	TERMOSTAT RF VS20WRF ALB	BUC	36
16	CAP TERMOSTATIC WIRELESS MINI CU BATERII	BUC	50
17	REPETOR (AMPLIFICATOR) DE SEMNAL,MONTAJ APARENT	BUC	6
18	RECEPTOR PENTRU CENTRALA SAU POMPA	BUC	3
19	GATEWAY UGE600 COORDONATOR INCORPORAT	BUC	3
20	REPETOR (AMPLIFICATOR) DE SEMNAL,MONTAJ APARENT	BUC	6
21	RADIATOR OTEL 600/22/400, 910W	BUC	7
22	RADIATOR OTEL 600/22/500, 1138W	BUC	3
23	RADIATOR OTEL 600/22/600, 1366W	BUC	4
24	RADIATOR OTEL 600/22/800, 1821W	BUC	3
25	RADIATOR OTEL 600/22/1000, 2276W	BUC	11
26	RADIATOR OTEL 600/22/1200, 2731W	BUC	7
27	RADIATOR OTEL 600/22/1400, 3186W	BUC	4
28	PORTPROSOP 600/1200, 725W	BUC	2